

S. No.	RFP document reference(s) (Clause & Page no.)	Content of RFP requiring Clarification(s)	Clarification(s) sought by the bidder	Reply by Bank
1	Page no.06/10	Buyer added Bid Specific Additional Scope of Work	Kindly confirm about the Test Reports/Certification and testing of the Emission Control retrofit device	The emission control device/Equipment must be type approved for engine similar to Model DV2 make Kirloskar, 600KVA compatible as per the CPCB, recognized/approved laboratories as per Govt. guidelines.